

From

Chief Engineer, Canals,
Irrigation Works, Punjab,
Chandigarh.

To

Chairman-cum-Managing Director,
Nabha Power Ltd,
Patiala.

No. 4730

Dated Chandigarh, the 9th May 2008

Subject:- Approval of Water Linkage of 50 cusecs for 1320 MW
Rajpura Thermal Power Project.

Please refer to your letter No. 120/NPL dated 8.5.2008
on the subject cited.

2.0 Government of Punjab in the Department of Irrigation
agrees to provide 50 cusecs of water for 1320 MW Rajpura Thermal
Power Project. It is further added that keeping in view the canal
closures, the project authorities should plan water storage capacity
for a minimum period of 3 weeks.


Chief Engineer/Canals

Cc:- Secy Irrigation & Power, Punjab – for information pl.